


ProTran1

Instruction Manual

1000VDC ProLight™
1000VDC LED Safety Light

MODEL 101601-1



The ProLight™ should be installed on or near overhead doors, dc switches, stinger systems, overhead contact wire, third rail, tunnels, and more

Warning: This device is designed to use in conjunction with very high voltage applications. Improper use is dangerous and could result in injury and/or death. Always wear proper gloves and eye protection prior to installation.

Operation

- 1 – Identify DC Power source.
- 2 – Mount the ProLight™ in the area where indication of warning is required.
- 3 – Connect one wire to the main DC power source and the other wire to ground.

Safety Notes

1. Always inspect the unit prior to use. Check the integrity of the wire insulation for nicks or cuts, inspect the unit for any loose parts etc. If any problems are discovered have the unit repaired immediately.

DOCUMENT DATE 13-Nov-2008

ProTran1

152 Waterford Road
Blue Anchor, NJ 08037
(609) 704-1737
Fax (609) 704-0565
www.protran1.com